

Attestation

BREEAM®

On the 27th of December 2024 Eurofins Product Testing A/S received a sample of a non-wooden panel with the product name:

MaxiBeam

supplied by

Vtec Group Ltd

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 testing standards (See test report no.392-2024-00605401_C_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:

- **BREEAM® International: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM International: New Construction 2021, Technical Manual – SD250: Hea 02 Indoor Air Quality (version 6.0. of December 2021).
- **BREEAM® UK: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM UK: New Construction 2023, Technical Manual: Hea 02 Indoor Air Quality (version SD5079 issue 6.1 of June 2023).
- **BREEAM® NL: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM NL: Nieuwbouw en Renovatie Woningen 2023, Technical Manual: Hea 03 Gezonde binnenlucht (Version 1.01 of June 2023). (Version 1.01 of June 2023).
- **BREEAM® SE: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM SE: New Construction 2021, Technical Manual: Hea 02 Indoor Air Quality (version 6.0. of January 2023).
- **BREEAM® NOR: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM NOR: New Construction 2023, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.1 of November 2023).

4 March 2025



Laura Hartung Sørensen
Analytical Service Manager